



Certificate of Compliance

Certificate: 80016357

Master Contract: 249143

Project: 80187673

Date Issued: 2023-11-09

Issued to: CSI Solar Co., Ltd.
199 Lushan Road, SND
Suzhou, Jiangsu 215129
China
Attention: Yuan Zhou

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: *Simon Shen*
Simon Shen

PRODUCTS

CLASS - C531110 - POWER SUPPLIES-Photovoltaic Modules and Panels

CLASS - C531190 - POWER SUPPLIES-Photovoltaic Modules and Panels - Certified to US Standards

Photovoltaic modules with maximum DC system voltage of 1500 V, Safety Class II, Module Fire Performance Type 29.

Model Series:

CS3U-xxxPB-AG (xxx = 350 to 395 W),
CS3W-xxxMB-AG (xxx = 415 to 465 W),
CS3U-xxxMB-AG (xxx = 350 to 410 W),
CS3K-xxxMB-AG (xxx = 280 to 330 W),
CS3W-xxxPB-AG (xxx = 390 to 460 W),
CS3K-xxxPB-AG (xxx = 265 to 350 W),
CS3Y-xxxMB-AG (xxx = 465 to 510 W),
CS3Y-xxxPB-AG (xxx = 430 to 480 W),
CS6W-xxxMB-AG (xxx = 520 to 555 W),
CS6R-xxxMB-AG (xxx = 390 to 415 W),
CS7N-xxxMB-AG (xxx = 630 to 670 W),



Certificate: 80016357

Project: 80187673

Master Contract: 249143

Date Issued: 2023-11-09

CS7L-xxxMB-AG (xxx = 570 to 610 W),
 CS7N-xxxTB-AG (xxx = 650 to 720 W),
 CS7L-xxxTB-AG (xxx = 590 to 650 W),
 CS6W-xxxTB-AG (xxx = 540 to 600 W),
 CS6.1-72TB-xxx (xxx = 570 to 630 W),
 CS6.1-72TB-xxxH (xxx = 570 to 630 W),
 CS6.1-60TB-xxx (xxx = 470 to 525 W),
 CS6.1-54TB2-xxx (xxx = 430 to 475 W),
 CS6.1-72TD-xxx (xxx = 575 to 635 W),
 CS6.1-54TD2-xxx (xxx = 430 to 480 W).

Model Type	Maximum DC System Voltage (V)	Open Circuit Voltage (V)	Maximum power voltage (V)	Short Circuit Current (A)	Maximum power current (A)	Maximum Power (Watts)	Maxium overcurrent protection rating (A)
CS3U-350PB-AG	1500	46.6	39.2	9.51	8.94	350	25
CS3U-355PB-AG	1500	46.8	39.4	9.59	9.02	355	25
CS3U-360PB-AG	1500	47.0	39.6	9.67	9.10	360	25
CS3U-365PB-AG	1500	47.2	39.8	9.75	9.18	365	25
CS3U-370PB-AG	1500	47.4	40.0	9.83	9.26	370	25
CS3U-375PB-AG	1500	47.6	40.2	9.91	9.34	375	25
CS3U-380PB-AG	1500	47.8	40.4	9.99	9.42	380	25
CS3U-385PB-AG	1500	48.0	40.6	10.07	9.50	385	25
CS3U-390PB-AG	1500	48.6	40.8	10.17	9.56	390	25
CS3U-395PB-AG	1500	48.8	41.0	10.24	9.64	395	25
CS3W-415MB-AG	1500	47.7	39.7	11.22	10.46	415	25
CS3W-420MB-AG	1500	47.9	39.9	11.27	10.53	420	25
CS3W-425MB-AG	1500	48.1	40.1	11.32	10.6	425	25
CS3W-430MB-AG	1500	48.3	40.3	11.37	10.68	430	25
CS3W-435MB-AG	1500	48.5	40.5	11.42	10.75	435	25
CS3W-440MB-AG	1500	48.7	40.7	11.48	10.82	440	25
CS3W-445MB-AG	1500	48.9	40.9	11.54	10.89	445	25
CS3W-450MB-AG	1500	49.1	41.1	11.6	10.96	450	25
CS3W-455MB-AG	1500	49.3	41.3	11.66	11.02	455	25
CS3W-460MB-AG	1500	49.5	41.5	11.72	11.09	460	25
CS3W-465MB-AG	1500	49.7	41.7	11.78	11.16	465	25
CS3U-350MB-AG	1500	46.6	38.8	9.53	9.03	350	25
CS3U-355MB-AG	1500	46.8	39.0	9.61	9.11	355	25
CS3U-360MB-AG	1500	47.0	39.2	9.69	9.19	360	25
CS3U-365MB-AG	1500	47.2	39.4	9.77	9.27	365	25
CS3U-370MB-AG	1500	47.4	39.6	9.85	9.35	370	25
CS3U-375MB-AG	1500	47.6	39.8	9.93	9.43	375	25
CS3U-380MB-AG	1500	47.8	40.0	10.01	9.50	380	25



Certificate: 80016357
Project: 80187673

Master Contract: 249143
Date Issued: 2023-11-09

Model Type	Maximum DC System Voltage (V)	Open Circuit Voltage (V)	Maximum power voltage (V)	Short Circuit Current (A)	Maximum power current (A)	Maximum Power (Watts)	Maxium overcurrent protection rating (A)
CS3U-385MB-AG	1500	48.0	40.2	10.09	9.58	385	25
CS3U-390MB-AG	1500	48.2	40.4	10.17	9.66	390	25
CS3U-395MB-AG	1500	48.4	40.6	10.25	9.73	395	25
CS3U-400MB-AG	1500	48.6	40.8	10.33	9.81	400	25
CS3U-405MB-AG	1500	49.3	41.0	10.44	9.88	405	25
CS3U-410MB-AG	1500	49.5	41.2	10.52	9.96	410	25
CS3K-280MB-AG	1500	38.5	31.7	8.84	9.49	280	25
CS3K-285MB-AG	1500	38.7	31.9	8.94	9.57	285	25
CS3K-290MB-AG	1500	38.9	32.1	9.04	9.65	290	25
CS3K-295MB-AG	1500	39.1	32.3	9.14	9.73	295	25
CS3K-300MB-AG	1500	39.3	32.5	9.24	9.82	300	25
CS3K-305MB-AG	1500	39.5	32.7	9.33	9.90	305	25
CS3K-310MB-AG	1500	39.7	32.9	9.43	9.98	310	25
CS3K-315MB-AG	1500	39.9	33.1	9.52	10.06	315	25
CS3K-320MB-AG	1500	40.1	33.3	9.61	10.14	320	25
CS3K-325MB-AG	1500	40.3	33.5	9.71	10.22	325	25
CS3K-330MB-AG	1500	40.5	33.7	9.80	10.33	330	25
CS3W-390PB-AG	1500	46.8	38.3	10.74	10.19	390	25
CS3W-395PB-AG	1500	47.0	38.5	10.82	10.26	395	25
CS3W-400PB-AG	1500	47.2	38.7	10.9	10.34	400	25
CS3W-405PB-AG	1500	47.4	38.9	10.98	10.42	405	25
CS3W-410PB-AG	1500	47.6	39.1	11.06	10.49	410	25
CS3W-415PB-AG	1500	47.8	39.3	11.14	10.56	415	25
CS3W-420PB-AG	1500	48.0	39.5	11.26	10.64	420	25
CS3W-425PB-AG	1500	48.2	39.7	11.29	10.71	425	25
CS3W-430PB-AG	1500	48.4	39.9	11.32	10.78	430	25
CS3W-435PB-AG	1500	48.6	40.1	11.35	10.85	435	25
CS3W-440PB-AG	1500	48.7	40.3	11.4	10.92	440	25
CS3W-445PB-AG	1500	48.8	40.5	11.45	10.99	445	25
CS3W-450PB-AG	1500	49.0	40.7	11.53	11.06	450	25
CS3W-455PB-AG	1500	49.2	40.9	11.61	11.13	455	25
CS3W-460PB-AG	1500	49.4	41.1	11.69	11.2	460	25
CS3K-265PB-AG	1500	37.3	30.6	9.22	8.66	265	25
CS3K-270PB-AG	1500	37.5	30.8	9.30	8.77	270	25
CS3K-275PB-AG	1500	37.7	31.0	9.38	8.88	275	25
CS3K-280PB-AG	1500	37.9	31.2	9.47	8.98	280	25
CS3K-285PB-AG	1500	38.1	31.4	9.56	9.08	285	25
CS3K-290PB-AG	1500	38.9	32.3	9.49	8.98	290	25



Certificate: 80016357
Project: 80187673

Master Contract: 249143
Date Issued: 2023-11-09

Model Type	Maximum DC System Voltage (V)	Open Circuit Voltage (V)	Maximum power voltage (V)	Short Circuit Current (A)	Maximum power current (A)	Maximum Power (Watts)	Maxium overcurrent protection rating (A)
CS3K-295PB-AG	1500	39.1	32.5	9.57	9.08	295	25
CS3K-300PB-AG	1500	39.3	32.7	9.65	9.18	300	25
CS3K-305PB-AG	1500	39.5	32.9	9.73	9.28	305	25
CS3K-310PB-AG	1500	39.7	33.1	9.81	9.37	310	25
CS3K-315PB-AG	1500	39.9	33.3	9.89	9.46	315	25
CS3K-320PB-AG	1500	40.1	33.5	9.97	9.56	320	25
CS3K-325PB-AG	1500	40.9	33.7	10.21	9.65	325	25
CS3K-330PB-AG	1500	41.1	33.9	10.29	9.74	330	25
CS3K-335PB-AG	1500	41.3	34.1	10.37	9.83	335	25
CS3K-340PB-AG	1500	41.5	34.3	10.45	9.92	340	25
CS3K-345PB-AG	1500	41.7	34.5	10.52	10.00	345	25
CS3K-350PB-AG	1500	41.9	34.7	10.60	10.09	350	25
CS3Y-465MB-AG	1500	52.3	43.6	11.42	10.67	465	25
CS3Y-470MB-AG	1500	52.5	43.8	11.47	10.74	470	25
CS3Y-475MB-AG	1500	52.7	44.0	11.52	10.81	475	25
CS3Y-480MB-AG	1500	52.9	44.2	11.57	10.87	480	25
CS3Y-485MB-AG	1500	53.1	44.4	11.62	10.94	485	25
CS3Y-490MB-AG	1500	53.3	44.6	11.67	11.00	490	25
CS3Y-495MB-AG	1500	53.5	44.8	11.72	11.06	495	25
CS3Y-500MB-AG	1500	53.7	45.0	11.77	11.12	500	25
CS3Y-505MB-AG	1500	53.9	45.2	11.82	11.18	505	25
CS3Y-510MB-AG	1500	54.1	45.4	11.87	11.24	510	25
CS3Y-430PB-AG	1500	50.8	41.6	11.08	10.34	430	25
CS3Y-435PB-AG	1500	51.0	41.8	11.13	10.41	435	25
CS3Y-440PB-AG	1500	51.2	42.0	11.18	10.48	440	25
CS3Y-445PB-AG	1500	51.4	42.2	11.23	10.55	445	25
CS3Y-450PB-AG	1500	51.6	42.4	11.28	10.62	450	25
CS3Y-455PB-AG	1500	51.8	42.6	11.33	10.69	455	25
CS3Y-460PB-AG	1500	52.0	42.8	11.38	10.75	460	25
CS3Y-465PB-AG	1500	52.2	43.0	11.43	10.82	465	25
CS3Y-470PB-AG	1500	52.4	43.2	11.48	10.88	470	25
CS3Y-475PB-AG	1500	52.6	43.4	11.53	10.95	475	25
CS3Y-480PB-AG	1500	52.8	43.6	11.58	11.01	480	25
CS6W-520MB-AG	1500	48.4	40.5	13.70	12.84	520	30
CS6W-525MB-AG	1500	48.6	40.7	13.75	12.90	525	30
CS6W-530MB-AG	1500	48.8	40.9	13.8	12.96	530	30
CS6W-535MB-AG	1500	49.0	41.1	13.85	13.02	535	30
CS6W-540MB-AG	1500	49.2	41.3	13.90	13.08	540	30



Certificate: 80016357
Project: 80187673

Master Contract: 249143
Date Issued: 2023-11-09

Model Type	Maximum DC System Voltage (V)	Open Circuit Voltage (V)	Maximum power voltage (V)	Short Circuit Current (A)	Maximum power current (A)	Maximum Power (Watts)	Maxium overcurrent protection rating (A)
CS6W-545MB-AG	1500	49.4	41.5	13.95	13.14	545	30
CS6W-550MB-AG	1500	49.6	41.7	14.00	13.20	550	30
CS6W-555MB-AG	1500	49.8	41.9	14.05	13.26	555	30
CS6R-390MB-AG	1500	36.4	30.4	13.70	12.84	390	30
CS6R-395MB-AG	1500	36.6	30.6	13.77	12.91	395	30
CS6R-400MB-AG	1500	36.8	30.8	13.85	12.99	400	30
CS6R-405MB-AG	1500	37.0	31.0	13.93	13.07	405	30
CS6R-410MB-AG	1500	37.2	31.2	14.01	13.15	410	30
CS6R-415MB-AG	1500	37.4	31.4	14.09	13.23	415	30
CS7N-630MB-AG	1500	44.2	37.1	18.23	16.99	630	35
CS7N-635MB-AG	1500	44.4	37.3	18.27	17.03	635	35
CS7N-640MB-AG	1500	44.6	37.5	18.31	17.07	640	35
CS7N-645MB-AG	1500	44.8	37.7	18.35	17.11	645	35
CS7N-650MB-AG	1500	45.0	37.9	18.39	17.16	650	35
CS7N-655MB-AG	1500	45.2	38.1	18.43	17.2	655	35
CS7N-660MB-AG	1500	45.4	38.3	18.47	17.24	660	35
CS7N-665MB-AG	1500	45.6	38.5	18.51	17.28	665	35
CS7N-670MB-AG	1500	45.8	38.7	18.55	17.32	670	35
CS7L-570MB-AG	1500	40.1	33.7	18.17	16.93	570	35
CS7L-575MB-AG	1500	40.3	33.9	18.22	16.97	575	35
CS7L-580MB-AG	1500	40.5	34.1	18.27	17.02	580	35
CS7L-585MB-AG	1500	40.7	34.3	18.32	17.06	585	35
CS7L-590MB-AG	1500	40.9	34.5	18.37	17.11	590	35
CS7L-595MB-AG	1500	41.1	34.7	18.42	17.15	595	35
CS7L-600MB-AG	1500	41.3	34.9	18.47	17.2	600	35
CS7L-605MB-AG	1500	41.5	35.1	18.52	17.25	605	35
CS7L-610MB-AG	1500	41.7	35.3	18.57	17.29	610	35
CS7N-650TB-AG	1500	45.9	38.0	17.99	17.11	650	35
CS7N-655TB-AG	1500	46.1	38.2	18.04	17.15	655	35
CS7N-660TB-AG	1500	46.3	38.4	18.09	17.19	660	35
CS7N-665TB-AG	1500	46.5	38.6	18.14	17.23	665	35
CS7N-670TB-AG	1500	46.7	38.8	18.19	17.27	670	35
CS7N-675TB-AG	1500	46.9	39.0	18.24	17.31	675	35
CS7N-680TB-AG	1500	47.1	39.2	18.29	17.35	680	35
CS7N-685TB-AG	1500	47.3	39.4	18.34	17.39	685	35
CS7N-690TB-AG	1500	47.5	39.6	18.39	17.43	690	35
CS7N-695TB-AG	1500	47.7	39.8	18.44	17.47	695	35
CS7N-700TB-AG	1500	47.9	40.0	18.49	17.51	700	35



Certificate: 80016357
Project: 80187673

Master Contract: 249143
Date Issued: 2023-11-09

Model Type	Maximum DC System Voltage (V)	Open Circuit Voltage (V)	Maximum power voltage (V)	Short Circuit Current (A)	Maximum power current (A)	Maximum Power (Watts)	Maxium overcurrent protection rating (A)
CS7N-705TB-AG	1500	48.1	40.2	18.54	17.55	705	35
CS7N-710TB-AG	1500	48.3	40.4	18.59	17.59	710	35
CS7N-715TB-AG	1500	48.5	40.6	18.64	17.63	715	35
CS7N-720TB-AG	1500	48.7	40.8	18.69	17.67	720	35
CS7L-590TB-AG	1500	41.7	34.5	18.01	17.12	590	35
CS7L-595TB-AG	1500	41.9	34.7	18.06	17.16	595	35
CS7L-600TB-AG	1500	42.1	34.9	18.11	17.20	600	35
CS7L-605TB-AG	1500	42.3	35.1	18.16	17.24	605	35
CS7L-610TB-AG	1500	42.5	35.3	18.21	17.29	610	35
CS7L-615TB-AG	1500	42.7	35.5	18.26	17.33	615	35
CS7L-620TB-AG	1500	42.9	35.7	18.31	17.37	620	35
CS7L-625TB-AG	1500	43.1	35.9	18.36	17.41	625	35
CS7L-630TB-AG	1500	43.3	36.1	18.41	17.46	630	35
CS7L-635TB-AG	1500	43.5	36.3	18.46	17.5	635	35
CS7L-640TB-AG	1500	43.7	36.5	18.51	17.54	640	35
CS7L-645TB-AG	1500	43.9	36.7	18.56	17.58	645	35
CS7L-650TB-AG	1500	44.1	36.9	18.61	17.62	650	35
CS6W-540TB-AG	1500	50.6	41.5	13.47	13.02	540	30
CS6W-545TB-AG	1500	50.8	41.7	13.54	13.07	545	30
CS6W-550TB-AG	1500	51.0	41.9	13.59	13.13	550	30
CS6W-555TB-AG	1500	51.2	42.1	13.64	13.19	555	30
CS6W-560TB-AG	1500	51.4	42.3	13.69	13.24	560	30
CS6W-565TB-AG	1500	51.6	42.5	13.75	13.30	565	30
CS6W-570TB-AG	1500	51.8	42.7	13.81	13.35	570	30
CS6W-575TB-AG	1500	52.0	42.9	13.88	13.41	575	30
CS6W-580TB-AG	1500	52.2	43.1	13.93	13.46	580	30
CS6W-585TB-AG	1500	52.4	43.3	14.00	13.52	585	30
CS6W-590TB-AG	1500	52.6	43.5	14.06	13.57	590	30
CS6W-595TB-AG	1500	52.8	43.7	14.12	13.62	595	30
CS6W-600TB-AG	1500	53.0	43.9	14.18	13.68	600	30
CS6.1-72TB-570	1500	50.6	42.8	14.18	13.32	570	30
CS6.1-72TB-575	1500	50.8	43.0	14.24	13.38	575	30
CS6.1-72TB-580	1500	51.0	43.2	14.30	13.43	580	30
CS6.1-72TB-585	1500	51.2	43.4	14.36	13.48	585	30
CS6.1-72TB-590	1500	51.4	43.6	14.42	13.54	590	30
CS6.1-72TB-595	1500	51.6	43.8	14.48	13.59	595	30
CS6.1-72TB-600	1500	51.8	44.0	14.54	13.64	600	30
CS6.1-72TB-605	1500	52.0	44.2	14.60	13.69	605	30



Certificate: 80016357
Project: 80187673

Master Contract: 249143
Date Issued: 2023-11-09

Model Type	Maximum DC System Voltage (V)	Open Circuit Voltage (V)	Maximum power voltage (V)	Short Circuit Current (A)	Maximum power current (A)	Maximum Power (Watts)	Maxium overcurrent protection rating (A)
CS6.1-72TB-610	1500	52.2	44.4	14.66	13.74	610	30
CS6.1-72TB-615	1500	52.4	44.6	14.72	13.79	615	30
CS6.1-72TB-620	1500	52.6	44.8	14.78	13.84	620	30
CS6.1-72TB-625	1500	52.8	45.0	14.84	13.89	625	30
CS6.1-72TB-630	1500	53.0	45.2	14.90	13.94	630	30
CS6.1-72TB-570H	1500	50.6	42.8	14.18	13.32	570	30
CS6.1-72TB-575H	1500	50.8	43.0	14.24	13.38	575	30
CS6.1-72TB-580H	1500	51.0	43.2	14.30	13.43	580	30
CS6.1-72TB-585H	1500	51.2	43.4	14.36	13.48	585	30
CS6.1-72TB-590H	1500	51.4	43.6	14.42	13.54	590	30
CS6.1-72TB-595H	1500	51.6	43.8	14.48	13.59	595	30
CS6.1-72TB-600H	1500	51.8	44.0	14.54	13.64	600	30
CS6.1-72TB-605H	1500	52.0	44.2	14.60	13.69	605	30
CS6.1-72TB-610H	1500	52.2	44.4	14.66	13.74	610	30
CS6.1-72TB-615H	1500	52.4	44.6	14.72	13.79	615	30
CS6.1-72TB-620H	1500	52.6	44.8	14.78	13.84	620	30
CS6.1-72TB-625H	1500	52.8	45.0	14.84	13.89	625	30
CS6.1-72TB-630H	1500	53.0	45.2	14.90	13.94	630	30
CS6.1-60TB-470	1500	42.0	35.4	14.09	13.28	470	30
CS6.1-60TB-475	1500	42.2	35.6	14.16	13.35	475	30
CS6.1-60TB-480	1500	42.4	35.8	14.23	13.42	480	30
CS6.1-60TB-485	1500	42.6	36.0	14.30	13.49	485	30
CS6.1-60TB-490	1500	42.8	36.2	14.37	13.55	490	30
CS6.1-60TB-495	1500	43.0	36.4	14.44	13.61	495	30
CS6.1-60TB-500	1500	43.2	36.6	14.51	13.67	500	30
CS6.1-60TB-505	1500	43.4	36.8	14.58	13.73	505	30
CS6.1-60TB-510	1500	43.6	37.0	14.65	13.79	510	30
CS6.1-60TB-515	1500	43.8	37.2	14.72	13.85	515	30
CS6.1-60TB-520	1500	44.0	37.4	14.79	13.91	520	30
CS6.1-60TB-525	1500	44.2	37.6	14.86	13.97	525	30
CS6.1-54TB2-430	1500	38.1	32.2	14.25	13.38	430	25
CS6.1-54TB2-435	1500	38.3	32.4	14.33	13.45	435	25
CS6.1-54TB2-440	1500	38.5	32.6	14.41	13.52	440	25
CS6.1-54TB2-445	1500	38.7	32.80	14.48	13.59	445	25
CS6.1-54TB2-450	1500	38.9	33.00	14.55	13.66	450	25
CS6.1-54TB2-455	1500	39.1	33.20	14.61	13.72	455	25
CS6.1-54TB2-460	1500	39.3	33.40	14.69	13.78	460	25
CS6.1-54TB2-465	1500	39.5	33.60	14.77	13.85	465	25



Certificate: 80016357
Project: 80187673

Master Contract: 249143
Date Issued: 2023-11-09

Model Type	Maximum DC System Voltage (V)	Open Circuit Voltage (V)	Maximum power voltage (V)	Short Circuit Current (A)	Maximum power current (A)	Maximum Power (Watts)	Maxium overcurrent protection rating (A)
CS6.1-54TB2-470	1500	39.7	33.80	14.86	13.91	470	25
CS6.1-54TB2-475	1500	39.9	34.00	14.94	13.98	475	25
CS6.1-72TD-575	1500	50.8	43.0	14.24	13.38	575	25
CS6.1-72TD-580	1500	51.0	43.2	14.30	13.43	580	25
CS6.1-72TD-585	1500	51.2	43.4	14.36	13.48	585	25
CS6.1-72TD-590	1500	51.4	43.6	14.42	13.54	590	25
CS6.1-72TD-595	1500	51.6	43.8	14.48	13.59	595	25
CS6.1-72TD-600	1500	51.8	44.0	14.54	13.64	600	25
CS6.1-72TD-605	1500	52.0	44.2	14.60	13.69	605	25
CS6.1-72TD-610	1500	52.2	44.4	14.66	13.74	610	25
CS6.1-72TD-615	1500	52.4	44.6	14.72	13.79	615	25
CS6.1-72TD-620	1500	52.6	44.8	14.78	13.84	620	25
CS6.1-72TD-625	1500	52.8	45.0	14.84	13.89	625	25
CS6.1-72TD-630	1500	53.0	45.2	14.90	13.94	630	25
CS6.1-72TD-635	1500	53.2	45.4	14.96	13.99	635	25
CS6.1-54TD2-430	1500	38.1	32.2	14.25	13.38	430	25
CS6.1-54TD2-435	1500	38.3	32.4	14.33	13.45	435	25
CS6.1-54TD2-440	1500	38.5	32.6	14.41	13.52	440	25
CS6.1-54TD2-445	1500	38.7	32.80	14.48	13.59	445	25
CS6.1-54TD2-450	1500	38.9	33.00	14.55	13.66	450	25
CS6.1-54TD2-455	1500	39.1	33.20	14.61	13.72	455	25
CS6.1-54TD2-460	1500	39.3	33.40	14.69	13.78	460	25
CS6.1-54TD2-465	1500	39.5	33.60	14.77	13.85	465	25
CS6.1-54TD2-470	1500	39.7	33.80	14.86	13.91	470	25
CS6.1-54TD2-475	1500	39.9	34.00	14.94	13.98	475	25
CS6.1-54TD2-480	1500	40.1	34.20	15.03	14.05	480	25

Note:

1. All electrical data are shown as relative to standard test conditions (STC) (1000 W/m², (25 ± 2) °C, AM 1.5 according to IEC 60904-3).
2. The manufacturer declared tolerance of Open-circuit voltage, Short-circuit current is ±5%, the manufacturer declared tolerance of Maximum power is ±3%.
3. The electrical power performance shown in the table above is only generated by front side of the PV module, more power may be generated if considering back side of the module.
4. The operating ambient temperature of these devices may exceed 40 °C at full load for all wire sizes if it is determined suitable in the field use application.



Certificate: 80016357
Project: 80187673

Master Contract: 249143
Date Issued: 2023-11-09

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61730-1:19	Photovoltaic (PV) module safety qualification - Part 1: Requirements for construction, 2019-12
CAN/CSA-C22.2 No. 61730-2:19	Photovoltaic (PV) module safety qualification - Part 2: Requirements for testing, 2019-12
UL 61730-1 First Edition	Photovoltaic (PV) Module Safety Qualification - Part 1: Requirements for Construction, 2017-12-04, revision date 2020-04-30
UL 61730-2 First Edition	Photovoltaic (PV) Module Safety Qualification - Part 2: Requirements for Testing, 2017-12-04, revision date 2020-04-30

Notes:

Products certified under Class C531110 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

